

# WATER QUALITY 2018



PWS# 0290065

## EXCELLENCE IN WATER QUALITY

Port O'Connor Improvement District 361-983-2652

GBRA Water Treatment Plant 361-552-9751

Dear Customer,

The Port O'Connor Improvement District (POCID) is pleased to provide you with the 2018 Water Quality Report (January 1-December 31, 2018). We take all possible precautions to safeguard your water supply and hope you will be encouraged to learn about the high quality of water provided to you.

The federal Safe Drinking Water Act (SDWA) requires water utilities to issue an annual report to customers, in addition to other notices that may be required by law. This report explains where your drinking water comes from, what it contains, and the health risks our water testing and treatment are designed to prevent.

We are committed to providing you with information about your water supply because informed customers are our best allies in supporting improvements needed to maintain the highest drinking water standards.

**We are proud to report that the Texas Commission on Environmental Quality (TCEQ) has assessed our system and determined that your drinking water, provided by the Port O'Connor Improvement District through the Guadalupe-Blanco River Authority's surface water treatment plant, meets or exceeds all federal and state water quality standards.**

The tables on this report list all substances that were detected in our treated water, and the highest level at which they were detected. The tables also reflect the highest levels allowed by federal regulatory agencies. Please read this information carefully and if you have questions, call the numbers listed in this report. An electronic version of this report can be found at [www.gbra.org/documents/publications/ccrs/2018/PortOConnor.pdf](http://www.gbra.org/documents/publications/ccrs/2018/PortOConnor.pdf)

### Customer Views Welcome

The POCID strongly supports the national primary water regulation compliance process. If you are interested in learning more about the water department, water quality, or participating in the decision-making process, there are a number of opportunities available.

Questions about water quality can be answered by calling the Improvement District at 361-983-2652 from 8 am – 5 pm, Monday through Friday. Inquiries about public participation and policy decisions should be directed to the District office in Port O'Connor at 39 Denman Dr., Box 375, Port O'Connor, Texas 77982. The District Directors hold their monthly meeting the third Tuesday of each month at 6:00 pm.

### En Español

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre este informe en español, favor de llamar al tel. 361-983-2652 para hablar con una personal bilingüe en español durante las horas regulares de oficina (8 am – 5 pm).

### CONSERVE WATER/SAVE WATER!

**Water Saving Tips:** Reduce indoor water usage by 40-50% by installing low-flush toilets and low flow fixtures

Water lawns once a week rather than a short period every day

Fix leaks and stop the dripping faucets

American Water Works Drip calculator to estimate water waste:

<https://drinktap.org/Water-Info/Water-Conservation/Drip-Calculator>



## Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## Where Do We Get Our Drinking Water?

POCID received its water from surface water diverted from the Guadalupe River and treated at the GBRA Port Lavaca Water Treatment Plant operated by the Guadalupe-Blanco River Authority (GBRA).

A Source Water Susceptibility Assessment for your drinking water source was conducted by TCEQ in 2004. This report describes the susceptibility and types of constituents that may come into contact with the drinking water source based on human activities and natural conditions. The system from which we purchase our water received the assessment report. For more information on source water assessments and protection efforts at our system contact GBRA Water Treatment Plant at 361-552-9751.

Trained operators monitor and test the water, including the addition of fluoride and chloramine, to ensure that our water meets or exceeds all state and federal drinking water standards. The treated water is delivered to the District's water storage tanks and delivered through its distribution system to you. For information on the treatment of your drinking water and water quality protection efforts, contact the GBRA Port Lavaca Water Treatment Plant at 361-552-9751.

## What We Found

The following tables list the contaminants that have been found in your drinking water. USEPA requires water systems to test for more than 97 contaminants. The column marked "Highest Level at Any Sampling Point" shows the highest test results during the year. The "Source of Contaminant" column shows where the substance usually originates.

### **DEFINITIONS and ABBREVIATIONS**

**Action Level (AL)** – the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Action Level Goal (ALG)** – The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

**Avg** – Regulatory compliance with some MCL's are based on running annual average of monthly samples.

**Maximum Contaminant Level (MCL)** – the highest level of the contaminant allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** – the level of a contaminant in drinking water below which there is no known or expected health risk. MCLG's allow for a margin of safety.

**Maximum residual disinfectant level or MRDL** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum residual disinfectant level goal or MRDLG** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**NA** – Not Applicable

**ND** – Not Detected

**NTU's** – Nephelometric Turbidity Units

**pCi/L** - picocuries per liter (a measure of radioactivity)

**ppm** – parts per million, or milligrams per liter (mg/L)

**ppb** – parts per billion (ug/L)

**Level 1 Assessment** – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system

**Level 2 Assessment** – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E.coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.



**TABLE I - Test results for the GBRA water supply to Port O'Connor Improvement District  
(Sampled at the GBRA Water Treatment Plant)**

Year	Detected Constituent	Measured Concentration	Number of Analyses	MCL	MCLG	Units of Measure	Violation	Source of Constituent
------	----------------------	------------------------	--------------------	-----	------	------------------	-----------	-----------------------

**Inorganics**

2018	Barium	0.07	1	2	2	ppm	N	Discharge of drilling wastes; erosion of natural deposits.
2018	Chromium	ND	1	100	100	ppb	N	Discharge from steel and pulp mills; erosion of natural deposits.
2018	Fluoride	0.66	1	4	4	ppm	N	Erosion of natural deposits; water additive which promotes strong teeth; runoff from fertilizer use.
2018	Nitrate	0.59	2	10	10	ppm	N	Runoff from fertilizer use; leaching from septic tanks; treated wastewater effluent; erosion of natural deposits.
2017	Gross Beta Emitters	5.6	1	50	0	pCi/l	N	Decay of mineral and man-made deposits.

**Organics**

Year	Detected Constituent	Concentration Detected	Number of Analyses	MCL	MCLG	Unit of Measure	Violation	Source of Constituent
2018	Atrazine	ND	1	3	3	ppb	N	Runoff from herbicide used on row crops.

**Unregulated Contaminants**

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. Any unregulated contaminants detected are reported in the following table. For additional information and data visit <http://www.epa.gov/safewater/ucmr/ucmr2/index.html>, or call the Safe Drinking Water Hotline at (800) 426-4791.

Year	Constituent	Average Concentration of Analysis	Range of Detected Levels	Reason for Monitoring
<b>Trihalomethanes</b>				
2018	Chloroform	13.4	8.6-18.5	Monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.
2018	Bromoform	4.52	ND-7.5	
2018	Bromodichloromethane	19.52	14.8-20.4	
2018	Chlorodibromomethane	18.28	21.5-25.0	
<b>Haloacetic Acids</b>				
2018	Chloroacetic acid	ND	ND	Monitoring helps EPA to determine where certain contaminants occur and whether it needs to regulate those contaminants.
2018	Dichloroacetic acid	11	7.2-14.1	
2018	Trichloroacetic acid	5.35	2.4-8.1	
2018	Bromoacetic acid	ND	ND	
2018	Dibromoacetic acid	5.32	1.8-7.6	
2018	Bromochloroacetic acid	8.32	5.8-10.6	

**Disinfection Byproducts**

Year	Constituent	Average level	Minimum level	Maximum level	MCL	Unit of Measure	Violation	Source of Contaminant
2018	Total Haloacetic Acids	2168	17.2	24.9	60	ppb	N	Byproduct of drinking water disinfection.
2018	Total Trihalomethanes	55.72	39.1	73.7	80	ppb	N	Byproduct of drinking water disinfection.

**Turbidity**

Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Year	Detected Constituent	Highest Single Measurement	Lowest Monthly % of Samples Meeting Limits	Turbidity Limits	Unit of Measure	Violation	Source of Constituent
2018	Turbidity	0.4	100	0.3	NTU	N	Organic particles.

**TOC (Total Organic Carbon)**

Total organic carbon (TOC) has no health effects. The disinfectant can combine with TOC to form disinfection byproducts. Disinfection is necessary to ensure that water does not have unacceptable levels of pathogens. Byproducts of disinfection include trihalomethanes (THM s) and haloacetic acids (HAA) which are reported elsewhere in this report.

Year	Detected Constituent	Average Measurement	Lowest Measurement	Highest Measurement	Units of Measurement	Source of Constituent
2018	Source Water TOC	4.07	2.36	5.95	ppm	Naturally occurring and there are no health effects directly associated with it.
2018	Drinking Water TOC	2.05	1.37	2.63	ppm	Naturally occurring and there are no health effects directly associated with it.
2018	Removal Ratio	2.44	1.46	3.19	%	NA

Removal ratio is the percent of TOC removed by the treatment process divided by the percent of TOC required by TCEQ to be removed.

**Disinfectant Residuals**

Year	Constituent	Highest Average	Range of Detects (low-high)	MRDL	MCLG	Units	Violation	Source of Constituent
2018	Chloramines	3.47	0.9-4.7	4	0	ppm	N	Disinfectant used to control microbes

**TOTAL COLIFORM**

Total coliform bacteria are used as indicators of microbial contamination of drinking water because testing for them is easy. While not disease-causing organisms themselves, they are often found in association with other microbes that are capable of causing disease. Coliform bacteria are more hardy than many disease-causing organisms, their absence from water is a good indication that the water is microbiologically safe for human consumption.

2018 TOTAL COLIFORM REPORTED MONTHLY TESTS FOUND NO COLIFORM BACTERIA  
 2018 E.coli REPORTED MONTHLY TESTS FOUND NO FECAL COLIFORM BACTERIA

**Violations Table**

No Violations

**Table II - Tests results for Port O'Connor Improvement District customers (As sampled in the Port O'Connor distribution system)**

**Inorganics**

Year	Detected Constituent	Highest Level Detected	Range of Individual Samples	MCL	MCLG	Unit of Measure	Violation	Source of Constituent
2016	Barium	0.0824	0.0824-0.0824	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
2016	Fluoride	0.64	0.64-0.64	4	4	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
2018	Nitrogen, Nitrate	0.39	0.39-0.39	10	10	ppm	N	Runoff from fertilizer use; leeching from septic tanks; treated wastewater effluent; erosion of natural deposits.

Nitrate Advisory - Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, you should ask advice from your health care provider.

**Radioactive Contaminants**

Year	Detected Constituent	Highest Level Detected	Range of Individual Samples	MCL	MCLG	Unit of Measure	Violation	Source of Constituent
2016	Beta/Photon emitters	8.1	8.1-8.1	50	0	pCi/L*	N	Decay of natural and man-made deposits.

\* EPA considers 50 pCi/L to be the level of concern for beta particles.

**Synthetic Organic Contaminants Including Pesticides and Herbicides**

Year	Detected Constituent	Highest Level Detected	Range of Individual Samples	MCL	MCLG	Unit of Measure	Violation	Source of Constituent
2017	Atrazine	0.23	0.23-0.23	3	3	ppb	N	Decay of natural and man-made deposits.

**Lead and Copper (Analyzed every 3 years)**

Year	Detected Constituent	The 90th Percentile	Number of Sites Exceeding Action	Action Level	Unit of Measure	Violation	Source of Constituent
2016	Lead	2.9	0	15	ppb	N	Corrosion of house hold plumbing systems; erosion of natural deposits
2016	Copper	0.31	1	13	ppm	N	Corrosion of house hold plumbing systems; erosion of natural deposits

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**Maximum Residual Disinfectant Level**

Systems must complete and submit disinfection data on the Surface Water Monthly Operations Report (SWMOR). On the CCR report, the system must provide disinfectant type, minimum, maximum, and average levels.

Year	Disinfectant	Average level	Minimum level	Maximum level	MRDL	Unit of Measure	Violation	Source of Constituent
2018	Chloramine Residual	1.61	0.5	5.2	4	ppm	N	Disinfectant used to control microbes.

**Total Trihalomethanes**

Year	Detected Constituent	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Unit of Measure	Violation	Source of Constituent
2018	Total Trihalomethanes	80	52.7-98.9	80	No Goal	ppb	N	By-product of drinking water chlorination.

**Haloacetic Acids (HAA5)**

Year	Detected Constituent	Highest Level Detected	Range of Detected Levels	MCL	MCLG	Unit of Measure	Violation	Source of Constituent
2018	Total Haloacetic Acids	29	1.3-32.4	60	No Goal	ppb	N	By-product of drinking water chlorination.

**Total Coliform**

Total coliform bacteria are used as indicators of microbial contamination of drinking water because testing for them is easy. While not disease-causing organisms themselves, they are often found in association with other microbes that are capable of causing disease. Coliform bacteria are more hardy than many disease-causing organisms, therefore, their absence from water is a good indication that the water is microbiologically safe for human consumption.

**Total Coliform** REPORTED MONTHLY TESTS FOUND ONE COLIFORM BACTERIA.  
**Fecal Coliform** REPORTED MONTHLY TESTS FOUND NO FECAL COLIFORM BACTERIA.

Violations Table			
Violation Type	Violation Begin	Violation End	Violation Explanation
Revised Total Coliform Rule (RTCR) Monitoring, Routine, Major	10/1/2018	10/31/2018	October's Bac-T report was not submitted under the monthly reports that are required by T.C.E.Q. We mistakenly reported under a Boil Water Requirement during that month. There was no threat to the public because of this mistake. It was reported in the wrong manner.

**Water Loss for the Port O'Connor Improvement District.**  
**38.738 MG (million gallons) for the year or 29.1 %**

**Secondary and Other Constituents Not Regulated**  
(No associated adverse health effects)

Year	Constituent	Measured Concentration	Number of Analyses	Secondary Limit	Unit of Measure	Source of Constituent
2018	Aluminum	716	1	50	ppb	Abundant naturally occurring element
2018	Bicarbonate	217	1	NA	ppm	Corrosion of carbonate rocks such as limestone.
2018	Calcium	76.8	1	NA	ppm	Abundant naturally occurring element.
2018	Chloride	89	1	300	ppm	Abundant naturally occurring element, used in water purification, byproduct of oil field activity.
2018	Copper	0.0495	1	NA	ppm	Corrosion of household plumbing systems; erosion from natural deposits; leaching from wood preservatives.
2018	Hardness as Ca/Mg	265	1	NA	ppm	Naturally occurring calcium and magnesium.
2018	Magnesium	17.9	1	NA	ppm	Abundant naturally occurring element.
2018	pH	7.7	1	7	units	Measure of corrosivity of water.
2018	Nickel	0.0029	1	0.1	ppm	
2018	Sodium	57.1	2	NA	ppm	Erosion of natural deposits. Byproduct of oil field activity.
2018	Zinc	ND	1	5	ppm	
2018	Sulfate	92	1	300	ppm	Naturally occurring, common industrial byproduct, byproduct of oil field activity.
2018	Total Alkalinity as CaCO3	178	1	NA	ppm	Naturally occurring soluble mineral salts.
2018	Total Dissolved Solids	468	1	1000	ppm	Total dissolved mineral constituents in water.
2018	Potassium	7.29	1	NA	ppm	
2018	Cyanide	ND	1	NA	ppm	
2018	Iron	ND	1	NA	ppm	Abundant naturally occurring element.

